

Certificate of Compliance

Certificate 20030904-R21261
Report Reference R21261, 2003 September 4
Issue Date 2009 March 13

Page 1 of 1



Issued to: SAMHOON CO LTD

577-1 SONGRAE 2 -DONG
SOSA-KU
BUCHEON-CITY KYUNGGI-DO KOREA

*This is to certify that
representative samples of*


**Single and pair swinging type stainless steel fire door
3Hr Fire Door**

*Have been investigated by Underwriters Laboratories in accordance with
the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: ANSI/UL 10B, NFPA 252

Additional Information: N/A

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Jaehan Bae*

Reviewed by: *Howard J. Gruszynski*

Jaehan Bae, Associate Project Engineer

Howard J. Gruszynski, Staff Engineer

UL Korea Ltd.

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.
For questions in Korea you may call +82-2-.



GSYX.R21261
Swinging Type Fire Doors

[Page Bottom](#)

[Print-friendly version](#)

[Questions?](#)

Swinging Type Fire Doors

[See General Information for Swinging Type Fire Doors](#)

SAMHOON MACHINERY CO
532-5 SIMGOKBON 1-DONG
BUCHHEON-SHI, SOSA-KU
KYUNGGI-DO, KOREA

R21261

Swinging type fire doors.

			Steel Covered
--	--	--	----------------------

Max Rating	Opening Type	Hollow Metal	Composite Type Door
3 Hr	Pair with Astragal	X	☐
	Steel or Stainless Steel		
	Rim, Mortise/Vertical Rod		
	Single Point Lock		
3 Hr	Single, Steel or Stainless Steel	X	☐
	Rim, Mortise Device		
	Single Point Lock		
1-1/2 Hr	Pair Door with	X	☐
	Max 100 sq in. of Glazing Material		
3/4 Hr	Pair Door with	X	☐
	Max 1296 sq in. of Glazing Material		

[Last Updated](#) on 2005-01-08

[Page Top](#)

[Notice of Disclaimer](#)

[Questions?](#)

UL Listed and Classified Products

UL Recognized Components

Products Certified for Canada

This page and all contents are Copyright © 2005 by Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2005 Underwriters Laboratories Inc.®"