

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE

DATE

17-May-11

TRANSMITTAL NO.


08 11 13.00 31 - 3.1

(Read instructions on reverse side prior to initiating this form)

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS *(This section will be initiated by the contractor)*

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.		CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8)	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION (See instruction No.6)	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b.	c.	d.	e.	f.	g.	h.	i.
7	STEEL FIRE RATED DOOR	Drawing & Data	5	2.7	A-603 ~ 605	A		B
a.	TYPE "B" THERMAL INSULATED METAL DOOR W/ METAL FRAME							
	45Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty,							
	Formed-In-Place Polyurethane Core, Impact And Thermal Resistance							
	Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design							
	#16GA. Steel Frame Knocked Down Unit, Double Rabbit							
	Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb							
	Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568							
	One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10							
	Cont'd							



REMARKS

I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated

CHO, JUN KI / CQC

NAME AND SIGNATURE OF CONTRACTOR

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <i>M. Benke con</i>	DATE 6/20/11
---------------------------------------	---	-----------------

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.		CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL

ITEM NO	DESCRIPTION OF ITEM SUBMITTED <small>(Type size, model number/etc.)</small>	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. <small>(See instruction no.8)</small>	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION <small>(See instruction No.6)</small>	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b.	c.	d.	e.	f.	g.	h.	i.
	Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend							
	Slim Trim Vision Kit for 100mm x 600mm Visible Size w/ Fire Rated Wire Glass							
	R. Opening Size : 1000mmW x 2150mmH							
	Door Size : 900mmW x 2100mmH x 44.5mmTHK RHR-3Sets							
	Model : SAMHOON "FG" Type Door							
	Steel Frame With DSN Wall Anchor Type							
	MFR : SAMHOON Co., Ltd.							
	P.O.U: STAIR#2 TO CORRIDOR-1(106) DOOR No.:D-4							
	STAIR#2 TO CORRIDOR-2(209) DOOR No.:D-8							
	STAIR#2 TO CORRIDOR-3(303) DOOR No.:D-19							

REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right; margin-top: 20px;"> CHO, JUN KI / CQC</div>
NAME AND SIGNATURE OF CONTRACTOR	

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <div style="text-align: center; margin-top: 10px;"> M. Bunde con</div>	DATE 6/20/11
---------------------------------------	--	------------------------

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
---	--	------------------------------------	---

SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.	CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL
---	--	---

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) c.	NO OF COPIES d.	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE g.	VARIATION (See instruction No.6) h.	FOR CE USE CODE i.
				SPEC PARA NO. e.	DRAWING SHEET NO. f.			
a.	b.							
b.	TYPE "B" THERMAL INSULATED METAL DOOR W/ METAL FRAME							
	45Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty,							
	Formed-In-Place Polyurethane Core, Impact And Thermal Resistance							
	Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design							
	#16GA. Steel Frame Knocked Down Unit, Double Rabbet							
	Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb							
	Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568							
	One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10							
	Cont'd							

REMARKS	<p>I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated</p> <p style="text-align: center;"><i>[Signature]</i> CHO, JUN KI / CQC</p> <p style="text-align: center;">NAME AND SIGNATURE OF CONTRACTOR</p>
---------	--

SECTION II-APPROVAL ACTION


ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <i>[Signature]</i>	DATE <i>6/20/11</i>
---------------------------------------	--	------------------------

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--


SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION: CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAЕ NAVAL BASE, KOREA.		CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOVT. APPROVAL

ITEM NO.	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no. 8)	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION (See instruction No. 6)	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b.	c.	d.	e.	f.	g.	h.	i.
	Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend							
	R. Opening Size : 1000mmW x 2150mmH							
	Door Size : 900mmW x 2100mmH x 44.5mmTHK RHR-1Set							
	Model : SAMHOON "FD" Type Door							
	Steel Frame With DSN Wall Anchor Type							
	MFR : SAMHOON Co., Ltd.							
	P.O.U: EXT. TO OPEN OFFICE-1(202)(208) DOOR No.:D-10							

REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div>
---------	--

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY 	DATE 6/20/11
---------------------------------------	---	------------------------


TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)


TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO. 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
---	--	------------------------------------	--

SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION: CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAЕ NAVAL BASE, KOREA.	CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL
---	---	--

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no. 8) c.	NO OF COPIES d.	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE g.	VARIATION (See instruction No. 6) h.	FOR CE USE CODE i.
				SPEC PARA NO. e.	DRAWING SHEET NO. f.			
a.	b.							
c.	TYPE "C" METAL FIRE RATED DOOR W/ METAL FRAME 60Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty, Formed-In-Place Ceramicwool Core, Impact And Thermal Resistance Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design #16GA. Steel Frame Knocked Down Unit, Double Rabbet Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568 One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10							
	Cont'd							

REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div>
---------	--

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY  con	DATE 6/20/11
---------------------------------------	--	------------------------

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE
 (Read instructions on reverse side prior to initiating this form)

DATE
17-May-11

TRANSMITTAL NO.
08 11 13.00 31 - 3.1

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO:
 Q.A.B CONSTRUCTION DIV.
 USAEDFE UNIT # 15546
 APO AP 96205-0610

FROM:
KRIMA CONSTRUCTION CORP.

CONTRACT NO:
2009MFH0220

CHECK ONE
 THIS IS A NEW TRANSMITTAL
 THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3

SPECIFICATION SEC. NO. (cover only one section with each transmittal) **08 11 13.00 31**

BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.

CHECK ONE: THIS TRANSMITTAL IS FOR FIO GOVT. APPROVAL

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) c.	NO OF COPIES d.	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE g.	VARIATION (See instruction No.6) h.	FOR CE USE CODE i.
				SPEC PARA NO. e.	DRAWING SHEET NO. f.			
a.	b.							
	Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend							
	Slim Trim Vision Kit for 100mm x 600mm Visible Size w/Fire Glass							
	R. Opening 1000mmW x 2150mmH							
	Door Size 900mmW x 2100mmH x 44.5mmTHK RHR-2Sets LHR-1Set							
	Model : SAMHOON "FG" Type Door							
	Steel Frame With DSN Wall Anchor Type							
	MFR : SAMHOON Co., Ltd.							
	P.O.U: CORRIDOR-1(106) TO STAIR#1 DOOR No.:D-5							
	STAIR#1 TO CORRIDOR-2(209)) DOOR No.:D-11							
	STAIR#1 TO CORRIDOR-3(303)) DOOR No.:D-20							

REMARKS

I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated

[Signature]
CHO, JUN KI / CQC

NAME AND SIGNATURE OF CONTRACTOR

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)

NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY
[Signature]
 com

DATE
6/20/11


TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)


TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
---	--	------------------------------------	--

SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.	CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOVT. APPROVAL
---	--	---

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8)	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION (See instruction No.6)	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b.	c.	d.	e.	f.	g.	h.	i.
d.	TYPE "C" METAL FIRE RATED DOOR W/ METAL FRAME							
	20Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty,							
	Formed-In-Place Ceramicwool Core, Impact And Thermal Resistance							
	Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design							
	#16GA. Steel Frame Knocked Down Unit, Double Rabbet							
	Concrete Wall Type, 4-Existing Opening Anchor (#EO/S6) Per Each Jamb							
	Hot-Dipped Galvanized Steel, Conforming To ASTM A924 & A568							
	One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10							
	Cont'd							

REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div>
---------	--

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY 	DATE 6/20/11
---------------------------------------	---	------------------------

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--


SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP .	CONTRACT NO: 2009MFH0220
---	---	------------------------------------


CHECK ONE
 THIS IS A NEW TRANSMITTAL
 THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3

SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN-N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.	CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL
---	--	---

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8)	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION (See instruction No.6)	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b.	c.	d.	e.	f.	g.	h.	i.
	Frame Size : 45mm Face & 146mm Depth w/ 13mm Backbend							
	R. Opening Size : 1000mmW x 2150mmH							
	Door Size : 900mmW x 2100mmH x 44.5mmTHK RHR-2Sets							
	Model : SAMHOON "FD" Type Door							
	Steel Frame With DSN Wall Anchor Type							
	MFR : SAMHOON Co., Ltd.							
	P.O.U: CORRIDOR-2(209) TO COMM.ROOM(208) DOOR No.:D-12							
	CORRIDOR-3(303) TO COMM.ROOM(302) DOOR No.:D-21							

REMARKS	<p>I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated</p> <p style="text-align: center;"> CHO, JUN KI / CQC</p> <p style="text-align: center;">NAME AND SIGNATURE OF CONTRACTOR</p>
---------	---

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY 	DATE 6/20/11
---------------------------------------	---	------------------------

TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
---	--	------------------------------------	---

SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAE NAVAL BASE, KOREA.	CHECK ONE: THIS TRANSMITTAL IS FOR <input type="checkbox"/> FIO <input checked="" type="checkbox"/> GOV'T. APPROVAL
---	--	---

ITEM NO	DESCRIPTION OF ITEM SUBMITTED <small>(Type size, model number/etc.)</small>	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. <small>(See instruction no.8)</small>	NO OF COPIES	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE	VARIATION <small>(See instruction No.6)</small>	FOR CE USE CODE
				SPEC PARA NO.	DRAWING SHEET NO.			
a.	b	c.	d.	e.	f.	g.	h.	i.
e.	TYPE "C" METAL FIRE RATED DOOR W/ METAL FRAME							
	45Min Fire Rated, U.L Labeled Class "B", #18GA. Level II, Heavy Duty,							
	Formed-In-Place Ceramicwool Core, Impact And Thermal Resistance							
	Mechanically Interlocked, Hemmed Vertical Edge Seam, Full Flush Design							
	#16GA. Steel Frame Knocked Down Unit, Double Rabbet							
	Dry Wall Type, 1/8" Increments with Steel Stud Anchor							
	Hot-Dipped Galvanized Steel, Conforming to ASTM A924 & A568							
	One Coat OF Oven-Cured Natural color Primer Paint, Conform with ANSIA250.10							
	Cont'd							

REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right; padding-right: 20px;"> CHO, JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div>
---------	--

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY <div style="text-align: center; padding: 10px;"> M. Bueh con</div>	DATE <div style="text-align: center; padding: 10px;">6/20/11</div>
---------------------------------------	--	--


TRANSMITTAL OF SHOP DRAWING, EQUIPMENT DATA, MATERIAL, SAMPLES, OR MANUFACTURE'S CERTIFICATES OF COMPLIANCE <small>(Read instructions on reverse side prior to initiating this form)</small>	DATE 17-May-11	TRANSMITTAL NO. 08 11 13.00 31 - 3.1
--	--------------------------	--

SECTION I-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS (This section will be initiated by the contractor)

TO: Q.A.B CONSTRUCTION DIV. USAEDFE UNIT # 15546 APO AP 96205-0610	FROM: KRIMA CONSTRUCTION CORP.	CONTRACT NO: 2009MFH0220	CHECK ONE <input type="checkbox"/> THIS IS A NEW TRANSMITTAL <input checked="" type="checkbox"/> THIS IS A RE-SUBMITTAL OF TRANSMITTAL 08 11 13.00 31 - 3
---	--	------------------------------------	--

SPECIFICATION SEC. NO. (cover only one section with each transmittal) 08 11 13.00 31	PROJECT TITLE AND LOCATION : CY07 ROK IN-KIND, PN N07R221 BACHELOR ENLISTED QUARTERS CHINHAЕ NAVAL BASE, KOREA.
---	--

ITEM NO	DESCRIPTION OF ITEM SUBMITTED (Type size, model number/etc.)	MFG OR CONTR. CAT. CURVE DRAWING OR BROCHURE NO. (See instruction no.8) c.	NO OF COPIES d.	CONTRACT REFERENCE DOCUMENT		FOR CONTRACTOR USE CODE g.	VARIATION (See instruction No.6) h.	FOR CE USE CODE i.
				SPEC PARA NO. e.	DRAWING SHEET NO. f.			
a.	b.							
	Frame Size : 45mm Face & 205mm Depth w/ 13mm Backbend							
	R. Opening Size : 1000mmW x 2150mmH							
	Door Size : 900mmW x 2100mmH x 44.5mmTHK LH-1Set							
	Model : SAMHOON "FD" Type Door							
	Steel Frame With DSH Steel Stud with Gypsum Board Type							
	MFR : SAMHOON Co., Ltd.							
	P.O.U: OFFICE(202) TO STORAGE(206)) DOOR No.:D-18							

REMARKS	I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as other wise stated <div style="text-align: right;">  CHO JUN KI / CQC NAME AND SIGNATURE OF CONTRACTOR </div>
---------	---

SECTION II-APPROVAL ACTION

ENCLOSURES RETURNED(List by Item No.)	NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY 	DATE 6/20/11
---------------------------------------	---	------------------------

TRANSMITTAL OF SHOP DRAWINGS, EQUIPMENT DATA, MATERIAL SAMPLES, OR MANUFACTURER'S CERTIFICATES OF COMPLIANCE		DATE 06/15/2011	TRANSMITTAL NO. 08 11 13.00 31-3.1
PROJECT TITLE	CY07 ROKC In-Kind Bachelor Quarters	CONTRACT NO. 2009-MFH-0220 NA	PAGE 1 of 1
LOCATION	Chinhae Naval Base, Korea		

<i>Item</i>	<i>Description</i>	<i>Variation</i>	<i>QA Code</i>
7	STEEL FIRE RATED DOOR	No	B

SECTION III - GOVERNMENT REVIEW REMARKS

1. Fire rated label shall be permanently affixed at the factory to frame and to the hinge edge of the door.
 2. Fire rated label shall be metal with raised letters, and shall bear the name or file number of the door and frame manufacturer.
 3. All surfaces of doors and frames shall be thoroughly cleaned, chemically treated and factory primed with a rust inhibiting coating as specified in SDI A250.8.
- CYK