SUBMITTAL REGISTER

Contract Number: W91QVN-11-D-0041-0021 Contractor : KOREA ENG. CONSULTANTS CORPORATION Date : 08-Dec-15

Project Title & Location : Repair Building No. 2602 at Camp Casey Specification Section : 093000,081113,081400, 085113

Submittal Identification	Specification Paragraph Number	Description of Submittal	Government Approval	For Information Only	Type of Submittal: Shop Drawing	Sample	Guarantee	MFR's Data	Certificate	Test Report	Other as noted	Source of Material: Local	Off-Shore	Contractor Scheduled Dates: Submit	Approval Needed by	Material needed by	TCOR: Action Code	Date	Remarks
LA-35		Glass Wool	X					X		X		X		8-Dec-15	15-Dec-15	22-Dec-15	A	9 Dec 15	
LA-36		Fire Sealant	X					X		X		X		8-Dec-15	15-Dec-15	22-Dec-15	A		
LA-37	2.3.4.2	Steel Door	X		X			X	X	X		X		8-Dec-15	15-Dec-15	22-Dec-15	G		
LA-38	2.3.4.2	Wood Door	X		X			X	X	X		X		8-Dec-15	15-Dec-15	22-Dec-15	G		
LA-39	2.3.7.3	Blast steel door	X		X			X	X	X		X		8-Dec-15	15-Dec-15	22-Dec-15	A		
LA-40	2.1	Blast AL window	X		X			X	X	X		X		8-Dec-15	15-Dec-15	22-Dec-15	A	9 Dec 15	
		******LAST ITEM******																	

IMCOM-K PW Form74, 19 June 2009

Reviewed by COR Kim, Tae Chong
COR,DPW,USAG-RC and Area 1
Typed Name, Signature and Date
9 Dec 15

Reviewed by TCOR Daniel C. Hong
Chief Eng. and Service Div.USAG RC and Area I
Typed Name, Signature and Date

TRANSMITTAL OF SHOP DRAWINGS, EQUIPMENT DATA, MATERIAL SAMPLES, OR MANUFACTURER'S CERTIFICATES OF COMPLIANCE

(Read instructions on the reverse side prior to initiating this form)

DATE: 8-Dec-15

TRANSMITTAL NO.: KECC-0021-10

SECTION 1-REQUEST FOR APPROVAL OF THE FOLLOWING ITEMS *(This section will be initiated by the contractor)*

TO: COR, DPW USAG-RC

FROM: KOREA ENG. CONSULTANS CORPORATION

CONTRACT NO.: W91QVN-11-D-0041-0021

CHECK ONE: ■ THIS IS A NEW TRANSMITTAL ☐ THIS A RESUBMITTAL OF TRANSMITTAL

SPECIFICATION SEC. NO. *(Cover only one section with each transmittal)*: 093000,081113,081400,085113

PROJECT TITLE AND LOCATION: Repair Building No. 2602 at Camp Casey

CHECK ONE: THIS TRANSMITTAL IS FOR ☐ FIO ■ GOV'T. APPROVAL

ITEM NO.	DESCRIPTION OF ITEM SUBMITTED *(Type size, model number / etc.)*	MFG OR CONTR. CAT., CURVE DRAWING OR BROCHURE NO. *(See instruction no. 8)*	NO. OF COPIES	CONTRACT REFERENCE DOCUMENT SPEC. PARA. NO.	CONTRACT REFERENCE DOCUMENT DRAWING SHEET NO.	FOR CONTRACTOR USE CODE	VARIATION *(See instruction No. 6)*	FOR CE USE CODE
a.	b.	c.	d.	e.	f.	g.	h.	i.
LA-39	Blast Steel doors							
	Size: R.O 1000*2200	MFG DATA	4	081113	A-15	A		A
	Type: Sing Manual Swing door w/glazing(100*750), only D9,D10							
	Blast design requirement: P: 40.6kPa, I: 210 kPa*msec							
	Test: Full scale blast test by HTL test laboratory							
	Air infiltration tested in accordance with ASTM E283							
	MFG: SAMHOON CO.LTD							
	POU: D9~D11							

REMARKS

PROJECT NO. : 96247

I certify that the above submitted items have been reviewed in detail and are correct and in strict conformance with the contract drawings and specifications except as otherwise stated.

Cho, Song Ho / CQC Manager

NAME AND SIGNATURE OF CONTRACTOR

SECTION II - APPROVAL ACTION

ENCLOSURES RETURNED (List by Item No.)

NAME, TITLE AND SIGNATURE OF APPROVING AUTHORITY

Daniel C. Hong, Chief, Eng. Service Div. USAG RC & Area I

DATE

(ER 415-1-10) EDITION OF SEP 93 IS OBSOLETE SHEET ___ OF ___ (Proponent:CEMP-CE)

ENG FORM 4025-R, Sep 93